

SERVICE REPORT

<p>The Kinson</p> <p>452 Saint Kilda Road Melbourne Victoria 3004</p>	<p>Report Number R-00236</p> <p>Reference</p> <p>Service Date: 18th April 2024</p>
--	---

Scope of Works
06 - Fire Detection Systems - FIP (2012): Monthly (1)

0 Critical Defects	A defect that renders a system inoperative.
1 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.

Servicing Summary		
Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly	
AS1851-2012 (a1) - Routine service of fire protection systems and equipment	

Asset		Status
15519	Ground, Sub FIP, Main FIP Room	FAIL

Asset**Status****Non-critical defect**ID: 818 [↗](#)

Added: 18th Apr 2024 4:35PM

Last Verified: 18th Apr 2024 4:37PM

Description:

Common/general visual/audible indications do not operate
Following devices in fault:L1 D155L1 D155.1L2 D12L2 D169L2 D169.1

Resolution:

Technician to investigate cause of issue and rectify where possible (excluding parts)

Location:

FIP

Logbooks**Fusion Sub FIP** [↗](#)

Classic Logbook

**Fusion Sub FIP** [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician**Date/Time****Accreditations****Signature**

Micra Fire
Technician

18th Apr 2024
4:35PM

Signatures

Denim

Company Accreditations: