

SERVICE REPORT

Australian Unity - Walmsley Community Centre

**Greeves Drive
 Kilsyth
 Victoria 3137**

Report Number R-00629

Reference WALMSLY-2401175

Service Date: 13th August 2024

Scope of Works

- 09 - Fire Hose Reels (2012): Six-monthly (1)
- 04 - Fire Hydrant Systems (2012): Six-monthly - Valves (2)
- Fire Detection Systems - FIP: Monthly (1)

0 Critical Defects	A defect that renders a system inoperative.
0 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.
1 Passed Assets	

Servicing Summary

Service	Asset	Quantity
09 - Fire Hose Reels (2012): Six-monthly	09 - Fire Hose Reels	1

Maintenance

09 - Fire Hose Reels (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset

Status

007 - Hose Reel 36m - 19mm - Fire

Entrance

PASS



Logbooks



06 - Fire Detection Systems [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician

Date/Time

Accreditations

Signature

Mike Alford

13th Aug 2024
3:45PM

Company Accreditations: