

SERVICE REPORT

Australian Unity - The Grace

**114 Albert Road
 Melbourne
 Victoria 3004**

**Report Number R-02014
 Reference GRACE-2400471
 Service Date:**

Scope of Works

10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly (83)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
79	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
239	Passed Assets	

Servicing Summary

Service	Asset	Quantity
10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly	10 - Fire Extinguishers - Portable	81

Maintenance

10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset

Status

160 - Fire Extinguisher DCP AB(E)
4.5KG

Bin room

FAIL



Non-conformance

ID: 2277 [↗](#)

Added: 14th Nov 2024 11:28AM

Last Verified: 14th Nov 2024 11:29AM

Description:

5-yearly pressure test overdue

Resolution:

158 - Fire Extinguisher DCP AB(E)
4.5KG

Mezzanine car park

FAIL



Non-conformance

ID: 2272 [↗](#)

Added: 14th Nov 2024 11:10AM

Last Verified: 14th Nov 2024 11:10AM

Description:

5-yearly pressure test overdue

Resolution:

159 - Fire Extinguisher DCP AB(E)
2.3KG

Sales office

FAIL



Non-conformance

ID: 2275 [↗](#)

Added: 14th Nov 2024 11:24AM

Last Verified: 14th Nov 2024 11:24AM

Description:

5-yearly pressure test overdue

Resolution:

Asset	Status
-------	--------

156 - Fire Extinguisher DCP AB(E)
4.5KG

Studio kitchen

PASS



157 - Fire Extinguisher DCP AB(E)
4.5KG

L17 Services

FAIL



Non-conformance

ID: 2217 [↗](#)

Added: 14th Nov 2024 8:25AM

Last Verified: 14th Nov 2024 8:25AM

Description:

5-yearly pressure test overdue

Resolution:

156 - Fire Extinguisher DCP AB(E)
4.5KG

Rooftop Entrance to stairwell


PASS



154 - Fire Extinguisher DCP AB(E)
4.5KG

L3 Services

FAIL



Non-conformance

ID: 2261 [↗](#)

Added: 14th Nov 2024 10:32AM

Last Verified: 14th Nov 2024 10:32AM

Description:

5-yearly pressure test overdue

Resolution:

153 - Fire Extinguisher DCP AB(E)
4.5KG

L4 Services

FAIL

Asset	Status
-------	--------



Non-conformance	Added: 14th Nov 2024 10:31AM
ID: 2258 ↗	Last Verified: 14th Nov 2024 10:31AM

Description:
5-yearly pressure test overdue

Resolution:

152 - Fire Extinguisher DCP AB(E) 4.5KG	Level 5 plant room	FAIL
---	--------------------	-------------



Non-conformance	Added: 14th Nov 2024 10:29AM
ID: 2255 ↗	Last Verified: 14th Nov 2024 10:29AM

Description:
5-yearly pressure test overdue

Resolution:

151 - Fire Extinguisher DCP AB(E) 4.5KG	Level 6 plant room	FAIL
---	--------------------	-------------




Non-conformance	Added: 14th Nov 2024 10:28AM
ID: 2251 ↗	Last Verified: 14th Nov 2024 10:28AM

Description:
5-yearly pressure test overdue

Resolution:

150 - Fire Extinguisher DCP AB(E) 4.5KG	Level 7 plant room	FAIL
---	--------------------	-------------



Asset		Status
Non-conformance ID: 2248 ↗		Added: 14th Nov 2024 10:26AM Last Verified: 14th Nov 2024 10:26AM
Description: 5-yearly pressure test overdue		
Resolution:		
149 - Fire Extinguisher DCP AB(E) 4.5KG	Level 8 plant room	FAIL
		
Non-conformance ID: 2245 ↗		Added: 14th Nov 2024 10:24AM Last Verified: 14th Nov 2024 10:24AM
Description: 5-yearly pressure test overdue		
Resolution:		
148 - Fire Extinguisher DCP AB(E) 4.5KG	Level 9 plant room	FAIL
		
Non-conformance ID: 2242 ↗		Added: 14th Nov 2024 10:22AM Last Verified: 14th Nov 2024 10:22AM
Description: 5-yearly pressure test overdue		
Resolution:		
146 - Fire Extinguisher DCP AB(E) 4.5KG	Level 11 plant room	FAIL
		
Non-conformance ID: 2236 ↗		Added: 14th Nov 2024 10:19AM Last Verified: 14th Nov 2024 10:20AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

145 - Fire Extinguisher DCP AB(E) Level 10 plant room
4.5KG

FAIL



<p>Non-conformance ID: 2239 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:21AM Last Verified: 14th Nov 2024 10:21AM</p>
--	--

144 - Fire Extinguisher DCP AB(E) Level 12 plant room
4.5KG

FAIL



<p>Non-conformance ID: 2234 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:18AM Last Verified: 14th Nov 2024 10:18AM</p>
--	--

143 - Fire Extinguisher DCP AB(E) Level 13 plant room
4.5KG

FAIL



<p>Non-conformance ID: 2230 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:17AM Last Verified: 14th Nov 2024 10:17AM</p>
--	--

142 - Fire Extinguisher DCP AB(E) Level 15 plant room
4.5KG

FAIL



Asset		Status
Non-conformance ID: 2221 ↗		Added: 14th Nov 2024 8:42AM Last Verified: 14th Nov 2024 8:42AM
Description: 5-yearly pressure test overdue		
Resolution:		
141 - Fire Extinguisher DCP AB(E) 4.5KG	Level 14 plant room	FAIL
		
Non-conformance ID: 2225 ↗		Added: 14th Nov 2024 8:47AM Last Verified: 14th Nov 2024 8:48AM
Description: 5-yearly pressure test overdue		
Resolution:		
140 - Fire Extinguisher DCP AB(E) 4.5KG	Level 17 plant room	FAIL
		
Non-conformance ID: 2215 ↗		Added: 14th Nov 2024 8:20AM Last Verified: 14th Nov 2024 8:20AM
Description: 5-yearly pressure test overdue		
Resolution:		
139 - Fire Extinguisher DCP AB(E) 4.5KG	Level 17 plant room	FAIL
		
Non-conformance ID: 2214 ↗		Added: 14th Nov 2024 8:18AM Last Verified: 14th Nov 2024 8:18AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

138 - Fire Extinguisher DCP AB(E) L16 Services
4.5KG

FAIL



Non-conformance
ID: 2219 [↗](#)

Added: 14th Nov 2024 8:37AM
Last Verified: 14th Nov 2024 8:37AM

Description:
5-yearly pressure test overdue

Resolution:

137 - Fire Extinguisher DCP AB(E) Pool filters room
2.5KG

FAIL



Non-conformance
ID: 2293 [↗](#)

Added: 14th Nov 2024 12:22PM
Last Verified: 14th Nov 2024 12:23PM

Description:
5-yearly pressure test overdue

Resolution:

136 - Fire Extinguisher DCP AB(E) L1 Carpark fan room
4.5KG

FAIL



Non-conformance
ID: 2269 [↗](#)

Added: 14th Nov 2024 10:47AM
Last Verified: 14th Nov 2024 10:48AM

Description:
5-yearly pressure test overdue

Resolution:

134 - Fire Extinguisher DCP AB(E) Pool handling unit
4.5KG

FAIL



Asset		Status
Non-conformance ID: 2268 ↗		Added: 14th Nov 2024 10:42AM Last Verified: 14th Nov 2024 10:42AM
Description: 5-yearly pressure test overdue		
Resolution:		
129 - Fire Extinguisher DCP AB(E) 4.5KG	Level 1 elevator	FAIL
		
Non-conformance ID: 2267 ↗		Added: 14th Nov 2024 10:38AM Last Verified: 14th Nov 2024 10:39AM
Description: 5-yearly pressure test overdue		
Resolution:		
127 - Fire Extinguisher DCP AB(E) 2.5KG	L2 AV store room	FAIL
		
Non-conformance ID: 2266 ↗		Added: 14th Nov 2024 10:35AM Last Verified: 14th Nov 2024 10:35AM
Description: 5-yearly pressure test overdue		
Resolution:		
111 - Fire Extinguisher DCP AB(E) 4.5KG	Mezzanine elevator	FAIL
		

Asset	Status
Non-conformance	Added: 14th Nov 2024 10:54AM
ID: 2271 ↗	Last Verified: 14th Nov 2024 10:54AM
Description: Location sign is missing / visible	
Resolution:	
	
Click photos to enlarge	
Non-conformance	Added: 14th Nov 2024 10:54AM
ID: 2270 ↗	Last Verified: 14th Nov 2024 10:54AM
Description: 5-yearly pressure test overdue	
Resolution:	
108 - Fire Extinguisher DCP AB(E) 4.5KG	Staff lockers ground
FAIL	
	
Non-conformance	Added: 14th Nov 2024 11:30AM
ID: 2278 ↗	Last Verified: 14th Nov 2024 11:30AM
Description: 5-yearly pressure test overdue	
Resolution:	
106 - Fire Extinguisher DCP AB(E) 4.5KG	Ground car park
FAIL	
	
Non-conformance	Added: 14th Nov 2024 11:34AM
ID: 2280 ↗	Last Verified: 14th Nov 2024 11:34AM
Description: 5-yearly pressure test overdue	
Resolution:	
105 - Fire Extinguisher DCP AB(E) 4.5KG	Maintenance parking
FAIL	

Asset	Status
-------	--------



Non-conformance	Added: 14th Nov 2024 11:33AM
ID: 2279 ↗	Last Verified: 14th Nov 2024 11:33AM

Description:
5-yearly pressure test overdue

Resolution:

103 - Fire Extinguisher DCP AB(E) 2.5KG	Admin	FAIL
---	-------	-------------



Non-conformance	Added: 14th Nov 2024 11:24AM
ID: 2276 ↗	Last Verified: 14th Nov 2024 11:24AM

Description:
5-yearly pressure test overdue

Resolution:

102 - Fire Extinguisher DCP AB(E) 4.5KG	Fire panel room	FAIL
---	-----------------	-------------



Non-conformance	Added: 14th Nov 2024 11:20AM
ID: 2274 ↗	Last Verified: 14th Nov 2024 11:20AM

Description:
5-yearly pressure test overdue

Resolution:

101 - Fire Extinguisher DCP AB(E) 4.5KG	Main entrance	FAIL
---	---------------	-------------



Asset		Status
Non-conformance ID: 2273 ↗		Added: 14th Nov 2024 11:18AM Last Verified: 14th Nov 2024 11:18AM
Description: 5-yearly pressure test overdue		
Resolution:		
230 - Fire Extinguisher DCP AB(E) 4.5KG	Grease interceptor trap room	FAIL
		
Non-conformance ID: 2292 ↗		Added: 14th Nov 2024 12:05PM Last Verified: 14th Nov 2024 12:05PM
Description: 5-yearly pressure test overdue		
Resolution:		
097 - Fire Extinguisher DCP AB(E) 4.5KG	Basement 1 elevators	FAIL
		
Non-conformance ID: 2281 ↗		Added: 14th Nov 2024 11:40AM Last Verified: 14th Nov 2024 11:43AM
Description: 5-yearly pressure test overdue		
Resolution:		
095 - Fire Extinguisher DCP AB(E) 4.5KG	Basement 1 storage cages	FAIL
		
Non-conformance ID: 2286 ↗		Added: 14th Nov 2024 11:42AM Last Verified: 14th Nov 2024 11:49AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

094 - Fire Extinguisher DCP AB(E)
4.5KG

Basement 1 elevators

FAIL



Non-conformance

ID: 2282 [↗](#)

Added: 14th Nov 2024 11:39AM
Last Verified: 14th Nov 2024 11:43AM

Description:

5-yearly pressure test overdue

Resolution:

093 - Fire Extinguisher DCP AB(E)
4.5KG

Badement 1 car park

FAIL



Non-conformance

ID: 2283 [↗](#)

Added: 14th Nov 2024 11:43AM
Last Verified: 14th Nov 2024 11:49AM

Description:

5-yearly pressure test overdue

Resolution:

086 - Fire Extinguisher DCP AB(E)
4.5KG

RW tank and pump room

FAIL



Non-conformance

ID: 2285 [↗](#)

Added: 14th Nov 2024 11:49AM
Last Verified: 14th Nov 2024 11:49AM

Description:

5-yearly pressure test overdue

Resolution:

085 - Fire Extinguisher DCP AB(E)
4.5KG

Basement 2 carpark west

FAIL



Asset		Status
Non-conformance ID: 2291 ↗		Added: 14th Nov 2024 11:59AM Last Verified: 14th Nov 2024 11:59AM
Description: 5-yearly pressure test overdue		
Resolution:		
083 - Fire Extinguisher DCP AB(E) 2.5KG	Basement 2 elevator	FAIL
		
Non-conformance ID: 2284 ↗		Added: 14th Nov 2024 11:45AM Last Verified: 14th Nov 2024 11:49AM
Description: 5-yearly pressure test overdue		
Resolution:		
081 - Fire Extinguisher DCP AB(E) 4.5KG	Hobby room	FAIL
		
Non-conformance ID: 2288 ↗		Added: 14th Nov 2024 11:50AM Last Verified: 14th Nov 2024 11:51AM
Description: 5-yearly pressure test overdue		
Resolution:		
080 - Fire Extinguisher DCP AB(E) 4.5KG	Basement 2 hallway to carpark	FAIL
		
Non-conformance ID: 2289 ↗		Added: 14th Nov 2024 11:51AM Last Verified: 14th Nov 2024 11:52AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

078 - Fire Extinguisher DCP AB(E) 4.5KG Fire pump room **FAIL**



Non-conformance ID: 2287 [↗](#) Added: 14th Nov 2024 11:47AM Last Verified: 14th Nov 2024 11:49AM

Description:
5-yearly pressure test overdue

Resolution:

078 - Fire Extinguisher DCP AB(E) 4.5KG Adjacent to fire pump room door **FAIL**



Non-conformance ID: 2290 [↗](#) Added: 14th Nov 2024 11:58AM Last Verified: 14th Nov 2024 11:58AM

Description:
5-yearly pressure test overdue

Resolution:

077 - Fire Extinguisher DCP AB(E) 4.5KG L2 Lobby cupboard **FAIL**



Non-conformance ID: 2263 [↗](#) Added: 14th Nov 2024 10:33AM Last Verified: 14th Nov 2024 10:33AM

Description:
5-yearly pressure test overdue

Resolution:

109 - Fire Extinguisher DCP AB(E) 2.5KG Entrance to Gym **FAIL**



Asset	Status
<p>Non-critical defect ID: 2265 ↗</p> <p>Description: Cylinder internal examination not in accordance with AS2030.5</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:34AM Last Verified: 14th Nov 2024 10:34AM</p>
<p>071 - Fire Extinguisher DCP AB(E) 4.5KG</p> <p>Cupboard near entrance to private dining</p>	<p>FAIL</p>
	
<p>Non-conformance ID: 2264 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:34AM Last Verified: 14th Nov 2024 10:34AM</p>
<p>070 - Fire Extinguisher DCP AB(E) 4.5KG</p> <p>L3 Hallway cupboard</p>	<p>FAIL</p>
	
<p>Non-conformance ID: 2260 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:32AM Last Verified: 14th Nov 2024 10:32AM</p>
<p>069 - Fire Extinguisher DCP AB(E) 4.5KG</p> <p>L5 Lobby cupboard</p>	<p>FAIL</p>
	
<p>Non-conformance ID: 2253 ↗</p> <p>Description: 5-yearly pressure test overdue</p> <p>Resolution:</p>	<p>Added: 14th Nov 2024 10:28AM Last Verified: 14th Nov 2024 10:29AM</p>

Asset	Status
-------	--------

067 - Fire Extinguisher DCP AB(E) L4 Lobby **FAIL**
4.5KG



Non-conformance Added: 14th Nov 2024 10:30AM
ID: 2256 [↗](#) Last Verified: 14th Nov 2024 10:30AM

Description:
5-yearly pressure test overdue

Resolution:

066 - Fire Extinguisher DCP AB(E) L2 Kitchen **FAIL**
4.5KG



Non-conformance Added: 14th Nov 2024 10:33AM
ID: 2262 [↗](#) Last Verified: 14th Nov 2024 10:33AM

Description:
5-yearly pressure test overdue

Resolution:

061 - Fire Extinguisher DCP AB(E) L6 Hallway cupboard **FAIL**
4.5KG



Non-conformance Added: 14th Nov 2024 10:28AM
ID: 2252 [↗](#) Last Verified: 14th Nov 2024 10:28AM

Description:
5-yearly pressure test overdue

Resolution:

060 - Fire Extinguisher DCP AB(E) L3 Lobby cupboard **FAIL**
4.5KG



Asset		Status
Non-conformance ID: 2259 ↗		Added: 14th Nov 2024 10:31AM Last Verified: 14th Nov 2024 10:31AM
Description: 5-yearly pressure test overdue		
Resolution:		
057 - Fire Extinguisher DCP AB(E) 4.5KG	L5 Hallway cupboard	FAIL
		
Non-conformance ID: 2254 ↗		Added: 14th Nov 2024 10:29AM Last Verified: 14th Nov 2024 10:29AM
Description: 5-yearly pressure test overdue		
Resolution:		
056 - Fire Extinguisher DCP AB(E) 4.5KG	L4 Hallway cupboard	FAIL
		
Non-conformance ID: 2257 ↗		Added: 14th Nov 2024 10:30AM Last Verified: 14th Nov 2024 10:30AM
Description: 5-yearly pressure test overdue		
Resolution:		
053 - Fire Extinguisher DCP AB(E) 4.5KG	L6 Lobby cupboard	FAIL
		
Non-conformance ID: 2250 ↗		Added: 14th Nov 2024 10:27AM Last Verified: 14th Nov 2024 10:27AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

052 - Fire Extinguisher DCP AB(E) L7 Lobby cupboard **FAIL**
4.5KG



Non-conformance ID: 2247 [↗](#) Added: 14th Nov 2024 10:26AM
Last Verified: 14th Nov 2024 10:26AM

Description:
5-yearly pressure test overdue

Resolution:

051 - Fire Extinguisher DCP AB(E) L7 Hallway cupboard **FAIL**
4.5KG



Non-conformance ID: 2249 [↗](#) Added: 14th Nov 2024 10:27AM
Last Verified: 14th Nov 2024 10:27AM

Description:
5-yearly pressure test overdue

Resolution:

045 - Fire Extinguisher DCP AB(E) L8 Hallway cupboard **FAIL**
4.5KG



Non-conformance ID: 2246 [↗](#) Added: 14th Nov 2024 10:24AM
Last Verified: 14th Nov 2024 10:24AM

Description:
5-yearly pressure test overdue

Resolution:

044 - Fire Extinguisher DCP AB(E) L8 Lobby cupboard **FAIL**
4.5KG



Asset		Status
Non-conformance ID: 2244 ↗		Added: 14th Nov 2024 10:23AM Last Verified: 14th Nov 2024 10:23AM
Description: 5-yearly pressure test overdue		
Resolution:		
041 - Fire Extinguisher DCP AB(E) 4.5KG	L9 Hallway cupboard	FAIL
		
Non-conformance ID: 2243 ↗		Added: 14th Nov 2024 10:22AM Last Verified: 14th Nov 2024 10:23AM
Description: 5-yearly pressure test overdue		
Resolution:		
040 - Fire Extinguisher DCP AB(E) 4.5KG	L9 Lobby cupboard	FAIL
		
Non-conformance ID: 2241 ↗		Added: 14th Nov 2024 10:22AM Last Verified: 14th Nov 2024 10:22AM
Description: 5-yearly pressure test overdue		
Resolution:		
037 - Fire Extinguisher DCP AB(E) 4.5KG	L10 Hallway cupboard	FAIL
		
Non-conformance ID: 2240 ↗		Added: 14th Nov 2024 10:21AM Last Verified: 14th Nov 2024 10:21AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

036 - Fire Extinguisher DCP AB(E)
4.5KG

L10 Lobby cupboard

FAIL



Non-conformance

ID: 2238 [↗](#)

Added: 14th Nov 2024 10:20AM
Last Verified: 14th Nov 2024 10:20AM

Description:

5-yearly pressure test overdue

Resolution:

033 - Fire Extinguisher DCP AB(E)
4.5KG

L11 Hallway cupboard

FAIL



Non-conformance

ID: 2237 [↗](#)

Added: 14th Nov 2024 10:20AM
Last Verified: 14th Nov 2024 10:20AM

Description:

5-yearly pressure test overdue

Resolution:

032 - Fire Extinguisher DCP AB(E)
4.5KG

L11 Lobby cupboard

FAIL



Non-conformance

ID: 2235 [↗](#)

Added: 14th Nov 2024 10:19AM
Last Verified: 14th Nov 2024 10:19AM

Description:

5-yearly pressure test overdue

Resolution:

029 - Fire Extinguisher DCP AB(E)
4.5KG

L12 Hallway cupboard

FAIL



Asset		Status
Non-conformance ID: 2233 ↗		Added: 14th Nov 2024 10:18AM Last Verified: 14th Nov 2024 10:18AM
Description: 5-yearly pressure test overdue		
Resolution:		
028 - Fire Extinguisher DCP AB(E) 4.5KG	L12 Lobby cupboard	FAIL
		
Non-conformance ID: 2232 ↗		Added: 14th Nov 2024 10:17AM Last Verified: 14th Nov 2024 10:17AM
Description: 5-yearly pressure test overdue		
Resolution:		
025 - Fire Extinguisher DCP AB(E) 4.5KG	L13 Hallway cupboard	FAIL
		
Non-conformance ID: 2231 ↗		Added: 14th Nov 2024 10:17AM Last Verified: 14th Nov 2024 10:17AM
Description: 5-yearly pressure test overdue		
Resolution:		
024 - Fire Extinguisher DCP AB(E) 4.5KG	L13 Lobby cupboard	FAIL
		
Non-conformance ID: 2229 ↗		Added: 14th Nov 2024 10:16AM Last Verified: 14th Nov 2024 10:16AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset	Status
-------	--------

021 - Fire Extinguisher DCP AB(E)
4.5KG

L14 Hallway cupboard

FAIL



Non-conformance
ID: 2226 [↗](#)

Added: 14th Nov 2024 8:48AM
Last Verified: 14th Nov 2024 8:48AM

Description:
5-yearly pressure test overdue

Resolution:

020 - Fire Extinguisher DCP AB(E)
4.5KG

L14 Lobby cupboard

FAIL



Non-conformance
ID: 2224 [↗](#)

Added: 14th Nov 2024 8:47AM
Last Verified: 14th Nov 2024 8:47AM

Description:
5-yearly pressure test overdue

Resolution:

017 - Fire Extinguisher DCP AB(E)
4.5KG

L15 Hallway cupboard

FAIL



Non-conformance
ID: 2222 [↗](#)

Added: 14th Nov 2024 8:42AM
Last Verified: 14th Nov 2024 8:42AM

Description:
5-yearly pressure test overdue

Resolution:

016 - Fire Extinguisher DCP AB(E)
4.5KG

L15 Lobby cupboard

FAIL



Asset		Status
Non-conformance ID: 2223 ↗		Added: 14th Nov 2024 8:43AM Last Verified: 14th Nov 2024 8:43AM
Description: 5-yearly pressure test overdue		
Resolution:		
013 - Fire Extinguisher DCP AB(E) 4.5KG	L16 Hallway cupboard	FAIL
		
Non-conformance ID: 2220 ↗		Added: 14th Nov 2024 8:37AM Last Verified: 14th Nov 2024 8:37AM
Description: 5-yearly pressure test overdue		
Resolution:		
012 - Fire Extinguisher DCP AB(E) 4.5KG	L16 Lobby cupboard	FAIL
		
Non-conformance ID: 2218 ↗		Added: 14th Nov 2024 8:33AM Last Verified: 14th Nov 2024 8:33AM
Description: 5-yearly pressure test overdue		
Resolution:		
009 - Fire Extinguisher DCP AB(E) 4.5KG	L17 Lobby cupboard	FAIL
		
Non-conformance ID: 2213 ↗		Added: 14th Nov 2024 8:16AM Last Verified: 14th Nov 2024 8:16AM
Description: 5-yearly pressure test overdue		
Resolution:		

Asset		Status
008 - Fire Extinguisher DCP AB(E) 4.5KG	L17 Hallway cupboard	FAIL



Non-conformance Added: 14th Nov 2024 8:21AM
 ID: 2216 [↗](#) Last Verified: 14th Nov 2024 8:21AM

Description:
5-yearly pressure test overdue

Resolution:

005 - Fire Extinguisher DCP AB(E) 4.5KG	Rooftop lobby cupboard	FAIL
--	------------------------	-------------



Non-conformance Added: 13th Nov 2024 8:23AM
 ID: 2182 [↗](#) Last Verified: 13th Nov 2024 8:23AM

Description:
5-yearly pressure test overdue

Resolution:

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	None		
Mike Alford	None		

Company Accreditations: