

SERVICE REPORT

Styleknit	Report Number R-00228
11/35 Dunlop Rd, Mulgrave VIC 3170, Australia	Reference
	Service Date: 19th April 2024

Scope of Works

11 - Fire Blankets (2012): Six-monthly (0)

0 Critical Defects	A defect that renders a system inoperative.
2 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	2

Maintenance

11 - Fire Blankets (2012): Six-monthly
 AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
002 - Fire Blanket 1.0M x 1.0M Micra air office	FAIL

Asset	Status
Non-critical defect ID: 871 ↗	Added: 23rd Apr 2024 4:02PM Last Verified: 23rd Apr 2024 4:06PM
Description: Fire blanket not installed	
Resolution: Technician to investigate cause of issue and rectify where possible (excluding parts)	
Location: Micra Air Office	
	
Click photos to enlarge	

002 - Fire Blanket 1.0M x 1.0M

Affinity 1st floor office

FAIL

Non-critical defect ID: 852 ↗	Added: 19th Apr 2024 3:08PM Last Verified: 19th Apr 2024 3:09PM
Description: Fire blanket not installed	
Resolution: Technician to investigate cause of issue and rectify where possible (excluding parts)	
	
Click photos to enlarge	

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Company Accreditations: