Micra Fire Pty Ltd
11/35 Dunlop Road Mulgrave VIC 3170
ABN: 43 661 051 494
03 9590 6100
service@micrafire.com.au
www.micraservice.com.au

SERVICE REPORT

Australian Unity - Geelong Grove Community Centre

50 Barwarre Road
Marshall
Victoria 3216

Report Number R-00300
Reference GEELONG-2400070
Service Date: 1st March 2024

Scope of Works

12 - Hinged and Pivoted Doorsets - Common (2012): Six-monthly (6)
Path of Travel & Discharge to Exit (2012): Quarterly (2)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
04 - Fire Hydrant Systems (2012): Annual Flow Test	04 - Fire Hydrant System	7

Maintenance

04 - Fire Hydrant Systems (2012): Annual Flow Test

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset		Status
10 - Hydrant Hydrant System Flow Test	Apt10	PASS Click photos to enlarge
6 - Hydrant Hydrant System Flow Test	Apt27	PASS Click photos to enlarge
5 - Hydrant Hydrant System Flow Test	Apt44	PASS Click photos to enlarge
4 - Hydrant Hydrant System Flow Test	Apt57	PASS Click photos to enlarge
3 - Hydrant Hydrant System Flow Test	Putting green	PASS Click photos to enlarge
2 - Hydrant Hydrant System Flow Test	Apt92	PASS Click photos to enlarge
1 - Hydrant Hydrant System Flow Test	Apt116	PASS Click photos to enlarge

Technician Notes

Please also include hydrant flow test. Base line = Wormald's recent testings, located in services cabinet.

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	1st Mar 2024 1:55PM		
Mike Alford	1st Mar 2024 1:55PM		

Company Accreditations: