

SERVICE REPORT

Styleknit	Report Number R-01738
Factory 10, 35 Dunlop Road	Reference
Mulgrave	Service Date: 28th November 2024
Victoria 3170	

Scope of Works
11 - Fire Blankets (2012): Six-monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
8	Passed Assets	

Servicing Summary		
Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	2

Maintenance		
11 - Fire Blankets (2012): Six-monthly		
AS1851-2012 (a1) - Routine service of fire protection systems and equipment		
Asset		Status
008 - Fire Blanket 1.0M x 1.0M	Level 1 kitchen	PASS

Asset	Status
	
002 - Fire Blanket 1.0M x 1.0M Styleknit ground floor	PASS



Repairs

002 - Fire Blanket 1.0M x 1.0M Styleknit ground floor	PASS
--	------



Click photos to enlarge

RESOLVED Non-critical defect Added: 19th Apr 2024 4:15PM
Last Verified: 19th Apr 2024 4:16PM

ID: 859 [↗](#)

Description:
Fire blanket not installed

Before	After
	

Click photos to enlarge

Parts/Labour	Quantity

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	28th Nov 2024 12:24PM		
Mike Alford	28th Nov 2024 12:24PM		

Company Accreditations: