

SERVICE REPORT

Australian Unity - Walmsley Aged Care

500 Greeves Drive
 Kilsyth
 Victoria 3137

Report Number R-00294
 Reference WALMS-AC2400334
 Service Date: 6th May 2024

Scope of Works

06 - Fire Detection Systems - FIP (2012): Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
001 - Fire Detection Panel Ampac - Firefinder Entrance	PASS

Logbooks



06 - Fire Detection Systems [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
------------	-----------	----------------	-----------

Micra Fire Technician	6th May 2024 3:26PM		
--------------------------	------------------------	--	--

Mike Alford	6th May 2024 3:26PM		
-------------	------------------------	--	--

Signatures

Denim

Company Accreditations: