

## SERVICE REPORT

**Australian Unity - Walmsley Community Centre**

**Greeves Drive  
 Kilsyth  
 Victoria 3137**

**Report Number R-00164  
 Reference WALMSLY-2400288  
 Service Date:**

### Scope of Works

- 06 - Fire Detection Systems - FIP (2012): Annual (1)
- 06 - Fire Detection Systems - FIP (2012): Annual - Survey (1)

<b>0</b>	<b>Critical Defects</b>	A defect that renders a system inoperative.
<b>0</b>	<b>Non-critical Defects</b>	A system impairment not likely to critically affect the operation of the system.
<b>1</b>	<b>Non-conformances</b>	Missing information or incorrect feature that does not affect the system operation.
<b>0</b>	<b>Recommendations</b>	A modification suggested to improve the system performance.
<b>0</b>	<b>Informational Notes</b>	Detailed advice or general comment.

### Servicing Summary

Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Annual - Survey	06 - Fire Detection Systems - Panels	1
06 - Fire Detection Systems - FIP (2012): Annual	06 - Fire Detection Systems - Panels	1

## Maintenance

### 06 - Fire Detection Systems - FIP (2012): Annual - Survey

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

#### Asset

#### Status

001 - Fire Detection Panel Ampac -  
Firefinder Plus

Serial: 2106762/03  
Entry

PASS

#### Non-conformance

Added: 3rd Apr 2024 8:35AM

ID: 699 [↗](#)

#### Description:

Update block plan to include zone list.

#### Resolution:

Supply and install new block plan

Quote: **SUBMITTED** [↗](#)

### 06 - Fire Detection Systems - FIP (2012): Annual

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

#### Asset

#### Status

001 - Fire Detection Panel Ampac -  
Firefinder Plus

Serial: 2106762/03  
Entry

FAIL

#### Non-conformance

Added: 3rd Apr 2024 8:35AM

ID: 699 [↗](#)

#### Description:

Update block plan to include zone list.

#### Resolution:

Supply and install new block plan

Quote: **SUBMITTED** [↗](#)

## Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	None		

### Company Accreditations: