

## SERVICE REPORT

**Australian Unity - Victoria Grange Residential Village (RC)**

**COMM CENTRE, BLOCK A,B,C**  
**502-514 Burwood Highway**  
**Vermont South**  
**Victoria 3133**

**Report Number R-00832**

**Reference VICGR-RC2401140**

**Service Date: 10th September 2024**

### Scope of Works

VICGR-RC2401140 - 11 - Fire Blankets (2012): Six-monthly (4)

0	<b>Critical Defects</b>	A defect that renders a system inoperative.
0	<b>Non-critical Defects</b>	A system impairment not likely to critically affect the operation of the system.
0	<b>Non-conformances</b>	Missing information or incorrect feature that does not affect the system operation.
0	<b>Recommendations</b>	A modification suggested to improve the system performance.
0	<b>Informational Notes</b>	Detailed advice or general comment.
66	<b>Passed Assets</b>	

### Servicing Summary

Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	5

## Maintenance

### 11 - Fire Blankets (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
-------	--------

069 - Fire Blanket 1.0M x 1.0M

Workshop

PASS



061 - Fire Blanket 1.8M x 1.8M

Community Center Outside BBQ area

PASS



054 - Fire Blanket 1.0M x 1.0M

Block C Lower Ground Hobby Room

PASS



017 - Fire Blanket 1.0M x 1.0M

Community Center Carpark Workshop

PASS



002 - Fire Blanket 1.0M x 1.0M

Community Center Kitchen

PASS



## Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	10th Sep 2024 12AM		
Mike Alford	10th Sep 2024 12AM		

### Company Accreditations: