

SERVICE REPORT

Australian Unity - Geelong Grove Community Centre

50 Barwarre Road
Marshall
Victoria 3216

Report Number R-00568

Reference GEELONG-2400534

Service Date: 14th August 2024

Scope of Works

Path of Travel & Discharge to Exit (2012): Annual (2)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
44	Passed Assets	

Servicing Summary


Service	Asset	Quantity
Path of Travel & Discharge to Exit (2012): Annual	12 - Path of Travel & Discharge to Exit	17

Maintenance

Path of Travel & Discharge to Exit (2012): Annual

Asset	Status
017 - Path of Travel & Discharge to Exit Discharge from Exit Community Centre	FAIL

Asset	Status
-------	--------




Non-critical defect
ID: 1324

Added: 14th Aug 2024 9:53AM
Last Verified: 14th Aug 2024 9:57AM

Description:
Door catching on top and bottom of the frame

Resolution:
Quote required to rectify defect required.

Location:
Community Center



016 - Path of Travel & Discharge to Exit Discharge from Exit	Community Centre	PASS
--	------------------	------



015 - Path of Travel & Discharge to Exit Discharge from Exit	Community Centre	PASS
--	------------------	------



014 - Path of Travel & Discharge to Exit Exit Door	Community Centre	PASS
--	------------------	------



013 - Path of Travel & Discharge to Exit Discharge from Exit	Community Centre	PASS
--	------------------	------



Asset		Status
012 - Path of Travel & Discharge to Exit Exit Door	Community Centre	PASS
		
011 - Path of Travel & Discharge to Exit Discharge from Exit	Community Centre	PASS
		
010 - Path of Travel & Discharge to Exit Exit Door	Community Centre	PASS
		
009 - Path of Travel & Discharge to Exit Discharge from Exit	Community Centre	PASS
		
008 - Path of Travel & Discharge to Exit Automatic Doors	Community Centre	PASS
		
007 - Path of Travel & Discharge to Exit Exit Door	Community Centre, cottage	PASS
		
006 - Path of Travel & Discharge to Exit Discharge from Exit	Workshop	PASS

Asset		Status
		
005 - Path of Travel & Discharge to Exit Exit Door	Workshop	PASS
		
004 - Path of Travel & Discharge to Exit Discharge from Exit	Men's Shed	PASS
		
003 - Path of Travel & Discharge to Exit Exit Door	Men's Shed	PASS
		
002 - Path of Travel & Discharge to Exit Discharge from Exit	Cottage	PASS
		
001 - Path of Travel & Discharge to Exit Exit Door	Cottage	PASS
		

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Mike Alford	14th Aug 2024 12AM		

Company Accreditations: