

SERVICE REPORT

Australian Unity - Walmsley Community Centre

**Greeves Drive
 Kilsyth
 Victoria 3137**

**Report Number R-00243
 Reference WALMSLY-2400442
 Service Date: 18th April 2024**

Scope of Works

06 - Fire Detection Systems - FIP (2012): Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
1	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
001 - Fire Detection Panel Ampac - Firefinder Plus Serial: 2106762/03 Entry	PASS

Asset**Status****Non-conformance**

Added: 3rd Apr 2024 8:35AM

ID: 699 [↗](#)**Description:**

Update block plan to include zone list.

Resolution:

Quote to rectify defect required

Quote: **ACTIONED** [↗](#)**Logbooks****06 - Fire Detection Systems** [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician**Date/Time****Accreditations****Signature**Micra Fire
Technician18th Apr 2024
4:41PM**Signatures**

Denim

Company Accreditations: