

SERVICE REPORT

Australian Unity - Victoria Grange Aged Care (AC)
 502 Burwood Hwy,
 Vermont South VIC 3133

Report Number R-00822
Reference VICGR-AC2401518
Service Date: 6th September 2024

Scope of Works

04 - Fire Hydrant Systems (2012): Six-monthly - Valves (2)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
14	Passed Assets	

Servicing Summary

Service	Asset	Quantity
04 - Fire Hydrant Systems (2012): Six-monthly - Valves	04 - Fire Hydrant System	2

Maintenance

04 - Fire Hydrant Systems (2012): Six-monthly - Valves

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
Booster - Hydrant Booster - Sprinkler Sprinkler valve room	PASS

Asset

Status



Suction - Hydrant Booster - Sprinkler

Sprinkler valve room

PASS



Photos



Click photos to enlarge

Signoff

Maintenance has been carried out in accordance with current regulations.

Signatures

Js

Company Accreditations: