

SERVICE REPORT

Australian Unity - Victoria Grange Aged Care (AC)
 502 Burwood Hwy,
 Vermont South VIC 3133

Report Number R-00818
Reference VICGR-AC2401518
Service Date: 16th September 2024

Scope of Works

Fire Detection Systems - FIP: Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
0	Passed Assets	

Servicing Summary

Service	Asset	Quantity
06 - Sound Systems (2012): Monthly	06 - Sound Systems	1

Maintenance

06 - Sound Systems (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
002 - Sound Systems Emergency Warning Intercom System (EWIS)	FAIL

Asset

Status

Non-critical defect

ID: 999 [↗](#)

Added: 18th Jun 2024 3:46PM

Last Verified: 18th Jun 2024 3:48PM

Description:

Battery out of date

Resolution:

Supply and install new batteries



[Click photos to enlarge](#)

Logbooks



06 - Fire Detection Systems [↗](#)

Classic Logbook



EWIS [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with current regulations.

Company Accreditations: