

SERVICE REPORT

<p>Australian Unity - Geelong Grove Community Centre</p> <p>50 Barwarre Road Marshall Victoria 3216</p>	<p>Report Number R-00336</p> <p>Reference GEELONG-2400281</p> <p>Service Date: 21st May 2024</p>
------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------

Scope of Works

Defect rectification work - Exit and Emergency Lights

0	Critical Defects	A defect that renders a system inoperative.
15	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Repairs Q-0030 [↗](#) ACTIONED

1 - Emergency Lighting Spitfire (Flush Mount) PASS

Community Centre, Reception

RESOLVED Non-critical defect	Added: 21st May 2024 10:23AM Last Verified: 21st May 2024 10:24AM
---------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------

Description:
 Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour	Quantity
--------------	----------

14 - Exit Sign Quick Fit (Wall Mount) - Exit

PASS

Community Centre, cottage

RESOLVED Non-critical defect

Added: 1st Mar 2024 12:28PM

ID: 228 [↗](#)

Last Verified: 1st Mar 2024 12:29PM

Description:

Emergency luminaire / exit sign not installed as required

Location:

Cottage

Parts/Labour	Quantity	
LED Jumbo Exit Light - 630mm x 320mm x 100mm	1.00	PERFORMED

15 - Emergency Lighting Spitfire (Flush Mount)

PASS

Cottage

RESOLVED Non-critical defect

Added: 1st Mar 2024 1:38PM

ID: 230 [↗](#)

Last Verified: 1st Mar 2024 1:39PM

Description:

Emergency luminaire / exit sign not operating as required

Parts/Labour	Quantity	
2x10W 2ft LED Emergency Light w Diffuser	1.00	PERFORMED

RESOLVED Non-critical defect

Added: 1st Mar 2024 1:38PM

ID: 229 [↗](#)

Last Verified: 1st Mar 2024 1:39PM

Description:

Emergency luminaire, not installed as required

Location:

Cottage

Parts/Labour	Quantity	
2x10W 2ft LED Emergency Light w Diffuser	1.00	PERFORMED

16 - Exit Sign Jumbo (Wall Mount) - Exit**PASS**

Men's Shed

RESOLVED Non-critical defect

Added: 1st Mar 2024 1:42PM

ID: 231 [↗](#)

Last Verified: 1st Mar 2024 1:43PM

Description:

exit sign not installed as required

Location:

Men shed

Parts/Labour**Quantity**

LED Jumbo Exit Light - 630mm x 320mm x 100mm

1.00

PERFORMED**17 - Emergency Lighting 2FT - Single Diffused Batten****PASS**

Men's Shed

RESOLVED Non-critical defect

Added: 1st Mar 2024 1:44PM

ID: 232 [↗](#)

Last Verified: 1st Mar 2024 1:45PM

Description:

Emergency luminaire not installed as required

Parts/Labour**Quantity**

2x10W 2ft LED Emergency Light w Diffuser

1.00

PERFORMED**18 - Exit Sign Jumbo (Wall Mount) - Exit****PASS**

Wirkshop

RESOLVED Non-critical defect

Added: 1st Mar 2024 1:47PM

ID: 233 [↗](#)

Last Verified: 1st Mar 2024 1:48PM

Description:

Exit sign not installed as required

Parts/Labour**Quantity**

LED Jumbo Exit Light - 630mm x 320mm x 100mm

1.00

PERFORMED

19 - Emergency Lighting 2FT - Single Diffused Batten

PASS

Workshop

RESOLVED

Non-critical defect

Added: 1st Mar 2024 1:49PM

ID: 234

Last Verified: 1st Mar 2024 1:50PM

Description:

Emergency luminaire not installed as required

Location:

Workshop

Parts/Labour

Quantity

2x10W 2ft LED Emergency Light w Diffuser

1.00

PERFORMED

4 - Emergency Lighting Spitfire (Flush Mount)

PASS

Community Centre

RESOLVED

Non-critical defect

Added: 21st May 2024 10:23AM

ID: 925

Last Verified: 21st May 2024 10:23AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

5 - Emergency Lighting Spitfire (Flush Mount)

PASS

Community Centre

RESOLVED

Non-critical defect

Added: 21st May 2024 10:23AM

ID: 926

Last Verified: 21st May 2024 10:23AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

7 - Emergency Lighting Spitfire (Flush Mount)

PASS

Community Centre, Hairdresser

RESOLVED

Non-critical defect

Added: 21st May 2024 10:24AM

ID: 928

Last Verified: 21st May 2024 10:24AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

8 - Emergency Lighting Spitfire (Flush Mount)

PASS

Community Centre, Consult Rm

RESOLVED Non-critical defect

Added: 21st May 2024 10:24AM

ID: 929

Last Verified: 21st May 2024 10:24AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

Ex1 - Exit Sign Quick Fit (Ceiling Mount) - Exit

PASS

Community Centre, Reception

RESOLVED Non-critical defect

Added: 21st May 2024 10:24AM

ID: 930

Last Verified: 21st May 2024 10:24AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

Ex4 - Exit Sign Quick Fit (Ceiling Mount) - Exit

PASS

Community Centre, out Consult Rm

RESOLVED Non-critical defect

Added: 21st May 2024 10:25AM

ID: 931

Last Verified: 21st May 2024 10:25AM

Description:

Emergency luminaire or exit sign did not meet the in-service duration of 90 minutes

Parts/Labour

Quantity

Ex5 - Exit Sign Quick Fit (Wall Mount) - Exit

PASS

Community Centre

RESOLVED Non-critical defect

Added: 1st Mar 2024 11:52AM

ID: 223

Last Verified: 1st Mar 2024 11:52AM

Description:

Emergency luminaire / exit sign not operating as required

Parts/Labour

Quantity

LED Quick Fit Exit Light

1.00

PERFORMED

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	21st May 2024 12AM		

Company Accreditations: