

SERVICE REPORT

Styleknit	Report Number R-00220
11/35 Dunlop Rd, Mulgrave VIC 3170, Australia	Reference
	Service Date: 19th April 2024

Scope of Works

10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly (0)

0 Critical Defects	A defect that renders a system inoperative.
0 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
1 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly	10 - Fire Extinguishers - Portable	2

Maintenance

10 - Portable and Wheeled Fire Extinguishers (2012): Six-monthly		
AS1851-2012 (a1) - Routine service of fire protection systems and equipment		
Asset		Status
003 - Fire Extinguisher DCP AB(E) 4.5KG	Micra air factory roller door	FAIL

Asset	Status
Non-conformance ID: 847 ↗	Added: 19th Apr 2024 2:48PM Last Verified: 19th Apr 2024 2:48PM
Description: 5-yearly pressure test overdue	
Resolution:	

004 - Fire Extinguisher DCP AB(E)
4.5KG

Affinity 1st floor office

PASS

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.