

## SERVICE REPORT

Australian Unity - Walmsley Aged Care

500 Greeves Drive  
 Kilsyth  
 Victoria 3137

Report Number R-00213  
 Reference WALMS-AC2400173  
 Service Date: 10th April 2024

### Scope of Works

06 - Fire Detection Systems - FIP (2012): Monthly (1)

0	<b>Critical Defects</b>	A defect that renders a system inoperative.
0	<b>Non-critical Defects</b>	A system impairment not likely to critically affect the operation of the system.
0	<b>Non-conformances</b>	Missing information or incorrect feature that does not affect the system operation.
0	<b>Recommendations</b>	A modification suggested to improve the system performance.
0	<b>Informational Notes</b>	Detailed advice or general comment.

### Servicing Summary

Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

## Maintenance

### 06 - Fire Detection Systems - FIP (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
001 - Fire Detection Panel Ampac - Firefinder Entrance	<b>PASS</b>

## Logbooks



06 - Fire Detection Systems [↗](#)

Classic Logbook

## Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
------------	-----------	----------------	-----------

Micra Fire Technician	10th Apr 2024 12:11PM		
--------------------------	--------------------------	--	--

## Signatures

Denim

Denim

Company Accreditations: