

SERVICE REPORT

Australian Unity - Walmsley Aged Care

500 Greeves Drive
 Kilsyth
 Victoria 3137

Report Number R-01037

Reference WALMS-AC2400694

Service Date: 4th October 2024

Scope of Works

WALMS-AC2400694 - FIP

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
3	Passed Assets	

Servicing Summary

Service	Asset	Quantity
Fire Detection Systems - FIP: Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

Fire Detection Systems - FIP: Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset

Status

001 - Fire Detection Panel Ampac -
Firefinder

Entrance

PASS



Photos



Click photos to enlarge

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician

Date/Time

Accreditations

Signature

Mike Alford

4th Oct 2024
12:43PM

Signatures

Js

Company Accreditations: