

SERVICE REPORT

Australian Unity - Campbell Place Aged Care (AC)

**131 Coleman Parade
 Glen Waverley
 Victoria 3150**

Report Number R-00798

Reference CAMB-AC2401349

Service Date: 4th September 2024

Scope of Works

CAMB-AC2401349 - Fire Blankets (2012): Six-monthly (9)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
65	Passed Assets	

Servicing Summary

Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	9

Maintenance

11 - Fire Blankets (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
037 - Fire Blanket 1.2M x 1.8M Kitchen	PASS

Asset	Status
	
030 - Fire Blanket 1.2M x 1.8M Apple kitchen	PASS
	
028 - Fire Blanket 1.2M x 1.8M Aubergine kitchen	PASS
	
FB G.2 - Fire Blanket 1.2M x 1.8M East ground kitchen	PASS
	
FB G.1 - Fire Blanket 1.2M x 1.8M East ground kitchen	PASS
	
FB.4 - Fire Blanket 1.2M x 1.8M Level 1 east kitchen	PASS
	
FB.3 - Fire Blanket 1.2M x 1.8M Level 1 East dining	PASS
	
FB.2 - Fire Blanket 1.2M x 1.8M Level 1 west The lodge room	PASS
	

Asset		Status
FB.1 - Fire Blanket 1.2M x 1.8M	Level 1 west dining	PASS



Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	4th Sep 2024 12AM		
Mike Alford	4th Sep 2024 12AM		

Company Accreditations: