

SERVICE REPORT

Australian Unity - Peninsula Grange

431 Racecourse Road
Mornington
Victoria 3931

Report Number R-00275
Reference PENG-RC-2400234
Service Date: 28th March 2024

Scope of Works

11 - Fire Blankets (2012): Six-monthly (0)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	2

Maintenance

11 - Fire Blankets (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
2 - Fire Blanket 1.0M x 1.0M Outside bbq area west	PASS

Asset		Status
1 - Fire Blanket 1.2M x 1.8M	Main Kitchen west	PASS

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	28th Mar 2024 12AM		
Mike Alford	28th Mar 2024 12AM		

Company Accreditations: