

SERVICE REPORT

<p>Australian Unity - Walmsley Aged Care</p> <p>500 Greeves Drive Kilsyth Victoria 3137</p>	<p>Report Number R-01725</p> <p>Reference</p> <p>Service Date:</p>
--	---

Scope of Works
11 - Fire Blankets (2012): Six-monthly (8)

0 Critical Defects	A defect that renders a system inoperative.
0 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.
80 Passed Assets	

Servicing Summary		
Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	8

Maintenance

11 - Fire Blankets (2012): Six-monthly		
AS1851-2012 (a1) - Routine service of fire protection systems and equipment		
Asset		Status
FB 34 - Fire Blanket 1.2M x 1.8M	Waratah Kitchen/dining area	PASS

Asset	Status
	
FB 32 - Fire Blanket 1.2M x 1.8M Fern Kitchen/dining area	PASS
	
FB 26 - Fire Blanket 1.2M x 1.8M Tulip Kitchen/dining area	PASS
	
FB 50 - Fire Blanket 1.2M x 1.8M Jacaranda Kitchen/dining area	PASS
	
FB 4 - Fire Blanket 1.2M x 1.8M Main Kitchen	PASS
	
FB 6 - Fire Blanket 1.2M x 1.8M Magnolia Kitchen/dining area	PASS
	
FB 19 - Fire Blanket 1.8M x 1.8M Protea Kitchen/dining area	PASS
	
FB 17 - Fire Blanket 1.8M x 1.8M Hydrangea Kitchen/dining area	PASS
	

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	None		

Company Accreditations: