

SERVICE REPORT

Australian Unity - Campbell Place Aged Care (AC)

131 Coleman Parade
 Glen Waverley
 Victoria 3150

Report Number R-00666

Reference CAMB-AC2401350

Service Date: 13th August 2024

Scope of Works

CAMB-AC2401350 - 09 - Fire Hose Reels (2012): Six-monthly (4)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
18	Passed Assets	

Servicing Summary

Service	Asset	Quantity
09 - Fire Hose Reels (2012): Six-monthly	09 - Fire Hose Reels	4

Maintenance

09 - Fire Hose Reels (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
051 - Hose Reel 36m - 19mm - Fire Car park west	PASS

Asset		Status
	048 - Hose Reel 36m - 19mm - Fire Training room, hallway	PASS
	047 - Hose Reel 36m - 19mm - Fire Car park East	PASS
	046 - Hose Reel 36m - 19mm - Fire Near kitchen exit door	PASS
		

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Mike Alford	13th Aug 2024 3:46PM		

Company Accreditations: