Micra Fire Pty Ltd
11/35 Dunlop Road Mulgrave VIC 3170
ABN: 43 661 051 494
03 9590 6100
service@micrafire.com.au
www.micraservice.com.au

SERVICE REPORT

Australian Unity - Victoria Grange Residential Aged Care (AC)

502 Burwood Hwy,
Vermont South VIC 3133

Report Number R-00481
Reference VICGR-AC2401036
Service Date: 12th July 2024

Scope of Works

06 - Sound Systems (2012): Monthly (1)
06 - Fire Detection Systems - FIP (2012): Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
0	Passed Assets	

Servicing Summary

Service	Asset	Quantity
06 - Sound Systems (2012): Monthly	06 - Sound Systems	1

Maintenance

06 - Sound Systems (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
002 - Sound Systems Emergency Warning Intercom System (EWIS)	FAIL

Non-critical defect
ID: 999

Added: 18th Jun 2024 3:46PM
Last Verified: 18th Jun 2024 3:48PM

Description:
Battery out of date

Resolution:
Supply and install new batteries

Click photos to enlarge

Logbooks

EWIS
Classic Logbook

06 - Fire Detection Systems
Classic Logbook

Signoff

Maintenance has been carried out in accordance with current regulations.

Technician	Date/Time	Accreditations	Signature
Mike Alford	12th Jul 2024 5:01PM		

Company Accreditations: