

SERVICE REPORT

Australian Unity - Walmsley Community Centre

Greeves Drive
 Kilsyth
 Victoria 3137

Report Number R-02134

Reference WALMSLY-2401744

Service Date: 2nd December 2024

Scope of Works

Fire Detection Systems - FIP: Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
1	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
1	Passed Assets	

Servicing Summary

Service	Asset	Quantity
Fire Detection Systems - FIP: Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

Fire Detection Systems - FIP: Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset

Status

001 - Fire Detection Panel Ampac -
Firefinder Plus

Serial: 2106762/03
Entry

PASS



Non-conformance

Added: 3rd Apr 2024 8:35AM

ID: 699 [↗](#)

Description:

Update block plan to include zone list.

Resolution:

Quote to rectify defect required

Quote: **ACTIONED** [↗](#)

Logbooks



06 - Fire Detection Systems [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	2nd Dec 2024 7:15PM		

Company Accreditations: