

SERVICE REPORT

<p>The Kinson</p> <p>452 Saint Kilda Road Melbourne Victoria 3004</p>	<p>Report Number R-00292 Reference APR KINSON Service Date: 12th April 2024</p>
---	--

Scope of Works	
06 - Fire Detection Systems - FIP (2012): Monthly (1)	

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary		
Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly	
AS1851-2012 (a1) - Routine service of fire protection systems and equipment	

Asset	Status
15519 Ground, Sub FIP, Main FIP Room	FAIL

Asset**Status****Non-critical defect**ID: 818 [↗](#)

Added: 18th Apr 2024 4:35PM

Last Verified: 18th Apr 2024 4:37PM

Description:

Common/general visual/audible indications do not operate
 Following devices in fault:L1 D155L1 D155.1L2 D12L2 D169L2 D169.1

Resolution:

Technician to investigate cause of issue and rectify where possible (excluding parts)

Location:

FIP

Logbooks**Fusion Sub FIP** [↗](#)

Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	12th Apr 2024 6:51AM		
Micra Air	12th Apr 2024 6:51AM		
Mike Alford	12th Apr 2024 6:51AM		

Signatures

Denim

Company Accreditations: