

## SERVICE REPORT

**Australian Unity - The Grace**

**114 Albert Road  
 Melbourne  
 Victoria 3004**

**Report Number R-02015  
 Reference GRACE-2400471  
 Service Date:**

### Scope of Works

11 - Fire Blankets (2012): Six-monthly (2)

0	<b>Critical Defects</b>	A defect that renders a system inoperative.
0	<b>Non-critical Defects</b>	A system impairment not likely to critically affect the operation of the system.
0	<b>Non-conformances</b>	Missing information or incorrect feature that does not affect the system operation.
0	<b>Recommendations</b>	A modification suggested to improve the system performance.
1	<b>Informational Notes</b>	Detailed advice or general comment.
239	<b>Passed Assets</b>	

### Servicing Summary

Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	3

### Maintenance

#### 11 - Fire Blankets (2012): Six-monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
156 - Fire Blanket 1.2M x 1.8M Studio kitchen	<b>FAIL</b>

**Asset** **Status**



**Informational** Added: 13th Nov 2024 7:48AM  
ID: 2179 [↗](#) Last Verified: 13th Nov 2024 7:48AM

**Description:**  
Requires yellow stamp tag

**Resolution:**

**065 - Fire Blanket 1.2M x 1.8M** L2 Kitchen **PASS**



**001 - Fire Blanket 1.2M x 1.8M** Rooftop Kitchen **PASS**



**Signoff**

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	None		
Mike Alford	None		

**Company Accreditations:**