

SERVICE REPORT

Styleknit	Report Number R-01734
11/35 Dunlop Rd, Mulgrave VIC 3170, Australia	Reference
	Service Date: 28th November 2024

Scope of Works

10 - Portable and Wheeled Fire Extinguishers (2012): Annual (2)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
4	Passed Assets	

Servicing Summary

Service	Asset	Quantity
10 - Portable and Wheeled Fire Extinguishers (2012): Annual	10 - Fire Extinguishers - Portable	2

Maintenance

10 - Portable and Wheeled Fire Extinguishers (2012): Annual
 AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
004 - Fire Extinguisher DCP AB(E) 4.5KG	Affinity 1st floor office PASS

Asset		Status
003 - Fire Extinguisher DCP AB(E) 4.5KG	Micra air factory roller door	PASS

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	28th Nov 2024 12:25PM		
Mike Alford	28th Nov 2024 12:25PM		

Company Accreditations: