

SERVICE REPORT

<p>The Kinson</p> <p>452 Saint Kilda Road Melbourne Victoria 3004</p>	<p>Report Number R-00132</p> <p>Reference</p> <p>Service Date: 21st February 2024</p>
--	--

Scope of Works
06 - Fire Detection Systems - FIP (2012): Monthly (1)

0 Critical Defects	A defect that renders a system inoperative.
0 Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0 Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0 Recommendations	A modification suggested to improve the system performance.
0 Informational Notes	Detailed advice or general comment.

Servicing Summary		
Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly	
AS1851-2012 (a1) - Routine service of fire protection systems and equipment	

Asset		Status
15519	Ground, Sub FIP, Main FIP Room	PASS

Logbooks



Fusion Sub FIP [↗](#)
Classic Logbook

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
------------	-----------	----------------	-----------

Micra Fire Technician	21st Feb 2024 9:37PM		
--------------------------	-------------------------	--	--

Mike Alford	21st Feb 2024 9:37PM		
-------------	-------------------------	--	--

Signatures

Hayden Rock

Company Accreditations: