

SERVICE REPORT

<p>Australian Unity - Drummond Place</p> <p>500 Drummond Street Carlton Victoria 3053</p>	<p>Report Number R-00882</p> <p>Reference DRUMOND-2400462</p> <p>Service Date: 24th September 2024</p>
--	---

Scope of Works	
11 - Fire Blankets (2012): Six-monthly (5)	

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.
359	Passed Assets	

Servicing Summary		
Service	Asset	Quantity
11 - Fire Blankets (2012): Six-monthly	11 - Fire Blankets	5

Maintenance		
11 - Fire Blankets (2012): Six-monthly		
AS1851-2012 (a1) - Routine service of fire protection systems and equipment		
Asset	Status	
019 - Fire Blanket 1.2M x 1.8M	Roof BBQ Area	PASS

Asset		Status
		
018 - Fire Blanket 1.0M x 1.0M	Roof BBQ Area	PASS
015 - Fire Blanket 1.0M x 1.0M	Ground Staff Kitchen	PASS
		
011 - Fire Blanket 1.0M x 1.0M	Ground Kitchen	PASS
F300228 - Fire Blanket 1.8M x 1.8M	Rooftop Terrace Barbecue Cupboard	PASS

Signoff

Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Service Technician	24th Sep 2024 12AM		

Company Accreditations: