

SERVICE REPORT

Australian Unity - Walmsley Community Centre

Greeves Drive
Kilsyth
Victoria 3137

Report Number R-00242
Reference WALMSLY-2400442
Service Date: 18th April 2024

Scope of Works

06 - Fire Detection Systems - FIP (2012): Monthly (1)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
1	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
06 - Fire Detection Systems - FIP (2012): Monthly	06 - Fire Detection Systems - Panels	1

Maintenance

06 - Fire Detection Systems - FIP (2012): Monthly

AS1851-2012 (a1) - Routine service of fire protection systems and equipment

Asset	Status
001 - Fire Detection Panel Ampac - Firefinder Plus Serial: 2106762/03 Entry	PASS

Asset	Status
Non-conformance ID: 699 ↗	Added: 3rd Apr 2024 8:35AM
Description: Update block plan to include zone list.	
Resolution: Quote to rectify defect required	
Quote: ACTIONED ↗	

Logbooks
 06 - Fire Detection Systems ↗ Classic Logbook

Signoff
Maintenance has been carried out in accordance with Part 15 of the Victorian Building Regulations 2018.

Technician	Date/Time	Accreditations	Signature
Micra Fire Technician	18th Apr 2024 4:41PM		

Signatures
 Denim

Company Accreditations: